



Testing. Advising. Assuring.

EWFA CERTIFICATE OF ASSESSMENT	CERTIFICATE No: SFC FAS180475.1 Page 1 of 1
---------------------------------------	---

Report Sponsor	Certificate Issue Date	Product Name
Unitex Granular Marble Pty Ltd 22 Park Drive Dandenong Vic 3175	9 November 2018	Unitex Panel Patch

Introduction

The element of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced Assessment Report(s) or Regulatory Information Report(s) for the complete description of the assessment construction.

Referenced Assessment Report	Test Methods	Report Issue Date	Report Validity Date
FAS180475.1	AS 1530.4-2014	9 November 2018	31 November 2023

Description of Assessment Product and Performance


The scope of the referenced assessment includes the fire resistance performance of joiner plates and angle brackets in concrete elements protected by Unitex panel patch if tested in general accordance with AS1530.4-2014 and AS4720.1-2005, on the basis of the discussion presented in the referenced assessment, it is the opinion of this testing authority that the proposed system would likely achieve the below results:

- The proposed joint construction is not directly under any nominated section in AS1530.4-2014 and AS4072.1-2005 for methods of fire test on building materials, components and structures. Therefore, an FRL cannot be directly attributed to the system. However, similar "integrity" and "insulation" performances as originally achieved when tested, would not be affected for the period of fire resistance of up to **240 minutes**.

Refer the referenced report for a complete description of the assessed construction.

Conditions/ Validity

- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Australia Pty Ltd	
Address	Unit 2, 409-411 Hammond Road, Dandenong, Melbourne, VIC 3175	
Phone / Fax	T: +61 (0)2 8270 7600 / F: +61 (0)2 9299 6076	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:	Reviewed By:
	 Rami Al Darwish	 Omar Saad

Description of assessed product and performance(Continued)

Refer to the referenced assessment report(s) or Regulatory Information Report(s) for a complete description of the assessed construction.