



Unitex
22 Park Drive
Dandenong VIC 3175

Phone: (03) 9768 4900
Fax (03) 9768 4999
www.unitex.com.au

Unitex (NSW)
14 Artisan Road
Seven Hills NSW 2147

Phone: (02) 9838 0911
Fax (02) 9838 9555
www.unitex.com.au

URW (Oakleigh)
1346 North Road
Oakleigh VIC 3167

Phone: 1800 RENDER
Fax (03) 9544 3620
www.render.com.au

URW (SA)
2/54-56 Cavan Road
Dry Creek SA 5094

Phone: 1800 RENDER
Fax (08) 8262 7922
www.render.com.au

VOC Content Test Certificate

Thursday, 10th September 2020

Supplier: Unitex Australia Pty Ltd (22 Park Drive, Dandenong, VIC, 3175, Australia)

Sample Description: Unitex[®] Panel Patch

Date Tested: 09th September 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory resting guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Unitex[®] Panel Patch
General purpose adhesive and sealants: 50 grams per Litre	2 grams per Litre as VOC content per material
<p><i>We hereby certify that Unitex[®] Panel Patch is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Tuan Duong
BE (Chem. Eng.)
Senior Consultant

Srikanth C. Srivatsa
BSc (Chemistry)
Scientific Consultant